

City Of Gardena
City Wide Facilities, HVAC Information

City Hall

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
West Basement						
AHU # 66	West Wall # 66	9 / 20 x 20 x 2	B 47			
AHU # 67	West Wall # 67	16 / 20 x 20 x 2	(2) B 64			
AHU # 3	South Wall	6 / 20 x 20 x 2	A 36			
IT / Storage Room		2 / 16 x 25 x 2				
Exhaust Fan	South Wall		A 32			
Air Compressor	Panel - CE - # 12		A 49			
East Basement						
AHU # 64	South Wall # 64	18 / 20 x 20 x 2				
AHU # 65	South Wall # 64	7 / 20 x 20 x 2				
Finance Lunch Room		1 / Washable				
Ext Main Chiller Unit						
	Unit Disconnect					

City Of Gardena
City Wide Facilities, HVAC Information

Police Department

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
South Basement						
AHU # 1 - Zone 68		9 / 20 x 20 x 2				
AHU # 2 - Zone 69		6 / 20 x 20 x 2				
Air Compressor			AX 51			
Exhaust Fan			4L340			

Penthouse Mechanical

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Jail AHU # 4 - Zone # 71	Unit Disconnect	9 / 20 x 20 x 2 9 / Pleets	(2) A 59			
Lobby AHU # 3 - Zone # 71	Unit Disconnect	2 / 20 x 20 x 2	A 44			

Roof Top

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
AC Unit # 1 - Chief Office	Unit Disconnect	4 / 16 x 16 x 2	AX 43			
AC Unit # 2 - Report Writing Room	Unit Disconnect	2 / 16 x 25 x 2	AX 39			
Police Records	Unit Disconnect	1 / 20 x 24 x 1				
Interior IT Room		Washable				
Exterior Service Garage		Washable				
6 - Exterior Trailer Units	Unit Disconnect	6 / 16 x 30 x 1				

City Of Gardena
City Wide Facilities, HVAC Information

Community Center

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Int Mechanical Room	North Wall	8 / 24 x 24 x 2				
Ext Mechanical Room						
Auditorium EAST	Unit Disconnect	4 / 16 x 20 x 2	BX 54			
Auditorium WEST	Unit Disconnect	4 / 2 x 20 x 2	BX 50			
Kitchen Blower Motor	Switch	4 / Washable				
Roof Top						
Package Unit #1 Room F	Unit Disconnect	1 / 20 x 25 x 1				
Package Unit #2 Room G	Unit Disconnect	2 / 20 x 20 x 1				

City Of Gardena
City Wide Facilities, HVAC Information

Public Works

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Roof Top	Unit Disconnect	2 / 18 x 24 x 2	(3) 3VX - 850			
		4 / 24 x 24 x 2	(3) 2L398G			
Rear Garage						
Unit # 1	Unit Disconnect	1 / 16 x 20 x 1				
Unit # 2	Unit Disconnect	1 / 16 x 20 x 1				

City Of Gardena

City Wide Facilities, HVAC Information

Human Services

Location		Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Roof Top							
Unit # 1	Main Office Area	Unit Disconnect	2 / 16 x 25 x 2	A 39			
Unit # 2	S/E Office Area	Unit Disconnect	2 / 16 x 25 x 2	A 36			
Unit # 3	N/E Office Area	Unit Disconnect	2 / 16 x 25 x 2	A 36			

City Wide Facilities, HVAC Information

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Roof Per Each Unit	Unit Disconnect	4 / 16 x 20 x 2	A-48			
6 Individual Units		Total 24 Filters	Toal 6 Belts			

City Of Gardena
City Wide Facilities, HVAC Information

Rowley Gymnasium

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Roof Top						
Gymnasium Unit #1	Unit Disconnect	1 / 16 x 20 x 2	A 43			
Gymnasium Unit #2	Unit Disconnect	2 / 16 x 25 x 2	A 43			
2 Individual Units		2 / 20 x 25 x 2				
Same Info Per Each Unit		1 / 20 x 20 x 2				
Gym Office Unit	Unit Disconnect	1 / Pleet	A 48			

Rowley Auditorium

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Mechanical Room						
Unit # 1 Split System	Unit Disconnect	3 / 16 x 25 x 2	A 48			

City Of Gardena
City Wide Facilities, HVAC Information

162nd - Western
Shopping Plaza

Location	Electrical Control	Filter Size	Belt Size	Bearings / Oil	Service Date	Remaing Stock
Suite # A	Unit Disconnect	1 / 16 x 20 x 1				
Suite # B						
Suite # C						
Suite # D						
Suite # E	Unit Disconnect	1 / 14 x 24 x 1				
Suite # F	Unit Disconnect	1 / 14 x 24 x 1				
Suite # G	Unit Disconnect	1 / 14 x 24 x 1				