



NOTES

1. BASE SHALL BE CRUSHED AGGREGATE BASE PER "STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION."
2. PORTLAND CEMENT CONCRETE SHALL BE CLASS 520-C-2500 PER "STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION."
3. THE FLOW LINE SHALL BE RAISED TWO INCHES AT THE MIDPOINT TO EXPEDITE DRAINAGE.
4. THE FLOW LINE SHALL HAVE AN 8" WIDE STEEL TROWEL FINISH & ALL OTHER HORIZONTAL SURFACES SHALL HAVE A COURSE BROOM FINISH.

CITY OF GARDENA

ENGINEERING DIVISION

TITLE:

CROSS GUTTER

APP. BY:

[Signature] 12/16/98
DATE

DESIGNED BY

DRAWN BY

CHECKED BY

A.W.D.

12/16/98

DWG.
NO.

ST - 3