



DEPARTMENT of PUBLIC WORKS

1717 WEST 162nd STREET / GARDENA, CALIFORNIA 90247-3731 / WWW.CITYOFGARDENA.ORG / PHONE (310) 217-9568

March 7, 2024

**REQUEST FOR PROPOSALS
STROM DRAIN MASTER PLAN (JN 523)**

ADDENDUM NO. 1

TO: ALL RFP SUBMITTERS:

ADDENDUM NO. 1, AS DESCRIBED BELOW, IS FOR THE USE OF CONSULTANT SUBMITTING RFP ON THIS PROJECT. ALL SUBMITTERS SHALL INDICATE ON THE PROPOSAL THAT THEY HAVE RECEIVED THIS ADDENDUM NO. 1

The following questions were received.

Question: Can we submit the schedule on 11x17 size page and count as 1 page in the 15-page requirement?

Answer: Yes

Question: What is the estimated total length of pipe that is owned and maintained by the City?

Answer: *Approximately 61,000 LF City and 91,000 LF County*

Question: Scope of Work Task 2 – “In addition, a smaller subset of critical or concerning pipes will require a more detailed review involving closed circuit television (CCTV) and potentially pipeline flushing.” In order to estimate the appropriate fees, what is the length of pipes that the consultant should assume that will require CCTV? What is the length of pipes that the consultant should assume that will require pipeline flushing?

Answer: *No pipeline flushing but CCTV all lines (City and County). Provide separate line-item cost for City lines and County lines.*

Question: Scope of Work Task 3 – “The consultant shall develop a calibrated hydrologic-hydraulic model for a range of return periods...” What are the return periods for this task?

Answer: *Please make a recommendation based on the industry standard.*

TASHA CERDA, Mayor / MARK E. HENDERSON, Mayor Pro Tem
RODNEY G. TANAKA, Councilmember / PAULETTE C. FRANCIS, Councilmember / WANDA LOVE, Councilmember
MINA SEMENZA, City Clerk / GUY MATO, City Treasurer / CLINT OSORIO, City Manager / CARMEN VASQUEZ, City Attorney

Question: Scope of Work Task 3 – For the hydrologic models, should the consultant follow the standards in the LA County Hydrology Manual?

Answer: *If that is what you recommend*

Question: Scope of Work Task 3 – “Dry and wet weather flow monitoring should be considered as part of this assessment.” For this proposal, how many locations should the consultant assume for the dry and wet weather flow monitoring?

Answer: *Based on consultant recommendation.*

Question: Does the City have a citywide topography map with contours that will be provided to the consultant? If so, what is the contour interval?

Answer: *No, consultant to provide*

Question: Evaluation and Selection Process – The table shows that Project Understanding/Schedule/Cost has a maximum score of 30 points. Is cost an evaluation criteria?

Answer: *Yes*

Question: Scope of Work task 2 stated that inventory and GIS database shall include County of Los Angeles lines/manholes and infrastructure within the City limits. Does Task 3 include evaluating these County of Los Angeles lines and infrastructures?

Answer: *Yes, it should include both City and LA County. Provide separate line-item cost for City lines and County lines.*

END OF ADDENDUM NO. 1
