

NOTES:

- ALL CONSTRUCTION SHALL BE IN CONFORMANCE WITH THE "SPPWC" LATEST EDITION.
- PCC SHALL BE 520-C-2500 PER "SPPWC" LATEST EDITION. ASPHALT AND CONCRETE TO BE REMOVED SHALL BE SAWCUT.
- 4. EX. CONCRETE SHALL BE REMOVED TO THE NEAREST SCOREMARK.
- 5. PLACE WEAKENED PLANE JOINTS (WPJ) EVENLY SPACED AT 10' O.C. MAX.
- 6. DWY INSTALLATION SHALL BE IN CONFORMANCE WITH THE DWY POLICY OF THE DEPARTMENT OF PUBLIC WORKS (ST-1).
- 7. CAB AND CMB TO 95% RELATIVE COMPACTION AND 90% SUBGRADE.
- 8. COARSE BROOM FINISH ON DRIVEWAY AND FINE HAIR BROOM FINISH ON SIDEWALK.
- "W"=10' MIN. & 35' MAX. (OR AS APPROVED) AND "X"=3' MIN.
- 10. "V" DIMENSION SHALL BE 2' MIN. & ESTABLISHED IN FIELD BASED ON "Y" DEPTH REQUIRED (Y=0.30' MAX., ADJUST TO MATCH FIELD CONDITIONS).
- 11. MIN. 20' OF FULL HEIGHT CURB REQUIRED BETWEEN DRIVEWAYS SERVING THE SAME LOT.
- 12. SAWCUT EXISTING CURB AT TOP OF "X" FOR JOIN.
- 13. IT MAY BE NECESSARY FOR APPROACH TO EXTEND ONTO PRIVATE PROPERTY TO INSURE 12% MAX. DRIVEWAY GRADE.
- 14. 24" OF ASPHALT TO BE R&R WHEN REPLACING C&G PORTION OF DRIVEWAY.

DWG NTS

CITY OF GARDENA APP. BY: DEPARTMENT OF PUBLIC WORKS Allan Rigg 9/16/2024 TITLE: RESIDENTIAL DRIVEWAY DESIGNED BY 09/24 DWG. ST-4DRAWN BY 09/24 NO. CHECKED BY ΚK 09/24