

FOR STANDARD CROSS GUTTER DETAIL  
REFER TO THE LATEST SPPWC

NOTES:

1. BASE SHALL BE CRUSHED AGGREGATE BASE PER "STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTIONS".
2. PORTLAND CEMENT COCRETE SHALL BE CLASS 520-C-2500 PER "STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTIONS".
3. THE FLOW LINE SHALL HAVE AN 8" WIDE STEEL TROWEL FINISH & ALL OTHER HORIZONTAL SURFACES SHALL HAVE A COURSE BROOM FINISH.
4. ABUTTING 24" WIDE A.C./A.B. SHALL BE SAWCUT AND REMOVED ADJACENT TO CROSS GUTTER CONSTRUCTION. THE A.C. PAVEMENT SHALL BE EX. THICKNESS + 1" (3" MIN., C2, PG 64-10), PLUS 8" CAB BELOW BOTTOM OF CROSS GUTTER REPLACED WITHIN 48 HOURS OF THE CONCRETE POUR, UNLESS A LONGER TIME IS APPROVED BY THE CITY ENGINEER.

<b>CITY OF GARDENA</b> <b>DEPARTMENT OF PUBLIC WORKS</b>	APP. BY: <div style="text-align: right; margin-top: 10px;"> <i>Allan Rigg</i>      9/16/2024  <hr style="width: 100%;"/>           CITY ENGINEER      DATE         </div>											
TITLE:  <div style="text-align: center; font-weight: bold; font-size: 1.2em;">CROSS GUTTER</div>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">DESIGNED BY</td> <td style="width: 10%;">KK</td> <td style="width: 10%;">09/24</td> <td rowspan="3" style="width: 15%; text-align: center; vertical-align: middle;"><b>DWG. NO.</b></td> <td rowspan="3" style="width: 32%; text-align: center; vertical-align: middle;"><b>ST-5</b></td> </tr> <tr> <td>DRAWN BY</td> <td>KK</td> <td>09/24</td> </tr> <tr> <td>CHECKED BY</td> <td>KK</td> <td>09/24</td> </tr> </table>	DESIGNED BY	KK	09/24	<b>DWG. NO.</b>	<b>ST-5</b>	DRAWN BY	KK	09/24	CHECKED BY	KK	09/24
DESIGNED BY	KK	09/24	<b>DWG. NO.</b>	<b>ST-5</b>								
DRAWN BY	KK	09/24										
CHECKED BY	KK	09/24										