



SECTION A-A

NOTES:

- 1. ALL CONSTRUCTION SHALL BE IN CONFORMANCE WITH THE "SPPWC" LATEST EDITION.
- 2. PCC SHALL BE 520-C-2500 PER "SPPWC" LATEST EDITION.
- 3. EXISTING CONCRETE SHALL BE REMOVED TO THE NEAREST SCOREMARK.
- 4. BASE SHALL BE CMB AND TO 95% RELATIVE COMPACTION. EX. SIDEWALK REPLACEMENT REQUIRES 90% MIN. COMPACTION ON EX. BASE MATERIAL.
- 5. "W" SHALL BE A MINIMUM OF 5' ON ARTERIAL & COLLECTOR STREETS, AND A MIN. OF 4' ON LOCAL STREETS.
- 6. FULL PKWY SIDEWALK, CONSTRUCTED PER STD ST-5B, IS PERMITTED FOR MULTIPLE RESIDENTIAL ZONES WHICH FRONT ON ARTERIAL OR COLLECTOR STREETS.
- 7. NO SAWCUT ON CONTROL LINES.
- 8. FINE HAIR BROOM FINISH ON SIDEWALK.
- NEW SIDEWALKS WILL REQUIRE CMB AND FOR REPLACEMENT OF EXISTING SIDEWALK, RE—COMPACT EXISTING BASE MATERIAL.

DWG NTS

CITY OF GARDENA APP. BY: DEPARTMENT OF PUBLIC WORKS Allan Rigg

CITY ENGINEER TITLE: RESIDENTIAL SIDEWALK DESIGNED BY 09/24 DWG. ST-6 DRAWN BY ΚK 09/24 NO. CHECKED BY ΚK 09/24